

## **CE – Declaration of Conformity**

CE-UKCA241015B Sense Pro 300x1200 Document:

Product Inspection: PI240104A Risk Assessment: RA21009B

We, **SG Armaturen AS** 

Skytterheia 25

N-4790 Lillesand - Norway

declare under sole responsibility that the product

Luminaire Type **Sense Pro 300x1200** Name(s)

To which this declaration relates is in conformity with the following EC-directive(s):

Directive 2014 / 30 / EU Directive 2014 / 35 / EU Directive 2009 / 125 / EF (Regs 244/2009, 245/2009, 347/2010)\* Electromagnetic compatibility (EMC) Low Voltage directive (LVD) Ecodesign requirements (ECO) \* As applicable and including amendments

RoHS 2011 / 65 / EU + RoHS III / EU 2015/863

The conformity of the product with the provisions of the directives is stated by the compliance with the following standards:

EN 60598-1:2021+A11:2022 (Luminaires - General requirements)

EN 60598-2-2:2012 (Luminaires - Recessed)

EN 60598-2-22:2014 (Luminaires – emergency lighting)

EN 62471:2008

(Luminaires – Photobiological safety of lamps and lamp systems)

EN 62493:2015 (EMF – Lighting equipment related to human exposure)

EN 55015:2019+A11:2020 (EMC - Radio disturbance)

EN 61000-3-2:2019 (EMC - Harmonics)

EN 61000-3-3:2013+A1:2019 (EMC - Voltage change, fluctuation & flicker)

EN 61547:2009 (EMC - Immunity)

CE declaration date: 2024

Statement of Conformity issued by SG Armaturen AS

Manufacturer Martin Ettrup Approval Engineer Lillesand, 15/10-2024 Place and date of issue Name of authorized person



## **UKCA – Declaration of Conformity**

Document: CE-UKCA241015B Sense Pro 300x1200

Product Inspection: PI240104A Risk Assessment: RA21009B

We, SG Armaturen AS

Skytterheia 25

N-4790 Lillesand - Norway

declare under sole responsibility that the product

Luminaire

Туре

Sense Pro 300x1200

Name(s)

To which this declaration relates is in conformity with the following UK-regulations:

UK SI 2016 No. 1091	UK SI 2016 No. 1101	UK SI 2010 No. 2617	UK SI 2012 No. 3032
The Electromagnetic Compatibility Regulations 2010	The Electrical Equipment (Safety) Regulations 2016	The Ecodesign for Energy-Related Products Regulations 2010 Equipment (Safety) Regulations 2016	The Restriction of the Use of Certain Hazardous Substances in Electrical Equipment Regulations 2012

The conformity of the product with the provisions of the directives is stated by the compliance with the following standards:

**EN 60598-1:2021+A11:2022** (Luminaires - General requirements)

**EN 60598-2-2:2012** (Luminaires - Recessed)

EN 60598-2-22:2014 (Luminaires – emergency lighting)

EN 62471:2008 (Luminaires – Photobiological safety of lamps and lamp systems)

**EN 62493:2015** (EMF – Lighting equipment related to human exposure)

**EN 55015:2019+A11:2020** (EMC - Radio disturbance)

**EN 61000-3-2:2019** (EMC - Harmonics)

**EN 61000-3-3:2013+A1:2019** (EMC – Voltage change, fluctuation & flicker)

**EN 61547:2009** (EMC - Immunity)

**UK SI 2021 No. 1095** (Luminaires – The Ecodesign for Energy-Related products

and Energy Information)

UKCA declaration date: 2024

Statement of Conformity issued by SG Armaturen AS

Manufacturer
Lillesand, 15/10-2024
Place and date of issue

Martin Ettrup
Approval Engineer

Name of authorized person

Signature of authorized person



## Declaration of Conformity statements/valid for the following products:

Product ID Number	Product Description	Article type	Article group
7021982126765 7021982126772	Sense Pro 300x1200 White Sense Pro 300x1200 White	3000K Ra>80 4000K Ra>80	703080 703080
Drivers			
7021988204900 7021988204917 7021988200834 7021988204924 7021988204047 7021988204931	Sense Driver White Sense Driver White Sense Driver White Sense Driver White Sense Driver White Sense Driver White	3000lm 26W 700mA Trailing 3000lm 26W 700mA Trailing 3000lm 26W 700mA DALI / F 4000lm 33W 900mA Trailing 4000lm 33W 900mA DALI / F 4000lm 32W 900mA edge dir	edge dimming Push Dim edge dimming Push Dim
Emergencybox			
5703821177344 5703821177276 5703821177504	Emergencybox Driver Emergencybox Emergencybox Driver	DALI / EM Emergency 3 hou On-Off/Trailing edge / EM Se DALI / EM DALI/Self test, Em	If test, Emergency 3h